



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail: igp-ladakh@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - PHQ/Dir/F&ES/UTL/2021- 3260-61

Dated:-07/12/2021

Subject: Fire NOC in favour of Mahabodhi School at Choglamsar, Leh.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the instant school which has been done by I/C Fire and Emergency Services, Leh. The detailed report is as under:

Location/ Accessibility:

The School building is constructed at Choglamsar, Leh. It is located at Longitude 77.616882 and Latitude 34.103511. The Site is approximately 08 Kms away from Fire and Emergency Services Station Leh. It takes 15 minutes to reach the site which is approachable for fire appliances.

Detail of building:

The School building has three blocks. Detail of block as under:

1st block: It is two storied School building having two stair cases. In the ground floor there are store room, sports room, kitchen and 8 class rooms. There are two windows in each class room and the size is 3'5"x6 feet. Two sides of the window have provision to open. 1st floor have store room, library, 3 no's of Science laboratory, maths laboratory and 4 class rooms.

2nd block: It is two storied building having two stair cases. In the ground floor there are PA system room having two windows and two exit doors, two class rooms having two windows and two exits doors, two no's of class rooms, computer room, four rooms for office, and store room with one window in each room. The size of window is 7x5 feet and 5x9 feet. Two sides of window have provision to open. 1st floor have Principal office and staff room.

3rd block: It is single storied building having 5 class rooms. There is one window in each room and the size is 8x5 feet. Two sides of the window have provision to open.

There are 490 students and 40 staffs in the School.

The following Fire Safety equipment's found installed in school Building:

01. 10 no's of ABC type fire extinguishers 6 kg capacity found installed in the School building.
02. 50 thousand litres underground reserve water tank found installed in the School premises.
03. 08 no's of sand bucket found installed in the school premises.
04. 0 no's of submersible bores with high rated pumps found installed in the school premises.

FIRE NOC is given in favor of Mahabodhi School at Choglamsar, Leh for a period of One year from the issuance of this letter.

Yaxup
07/12/21
Director, F&ES, Ladakh
PHQ, Agaling, Leh

Copy to:

1. Tsewang Dolma, Principal, Mahabodhi School at Choglamsar, Leh for info
2. Superintendent of Police, F&ES, Ladakh for information and n/a