



# THE ADMINISTRATION OF UNION TERRITORY OF LADAKH

## OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail-igp-ladakh@police.ladakh.gov.in)

(Office Phone No: 01982-260888)

No: PHQ/ Dir/F&ES/UTL/2023- 5479-80

Dated: 23/03/2023

### Subject: Fire NOC of Mahabodhi Residential School at Choglamsar, Leh.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the School which has been done by DFO Fire and Emergency Services, Leh. The detailed report is as under:

#### Location/ Accessibility:

The School building is constructed at Choglamsar, Leh. It is located at Longitude 77.616882 and Latitude 34.103511. The site is approximately 08 Kms from Fire and Emergency Services Station, Leh. It takes approximately 15 minutes to reach the site and is approachable for fire appliances.

#### Detail of building:

The School building have 03 blocks. The detail of the block is as under:

**1<sup>st</sup> block:** It is two storied building having two staircase. In the ground floor there are store room, sport room, kitchen and 8 number of class rooms. There are two window in each room and the size is 3'5"x6'. Two side of the window have provision to open. 1<sup>st</sup> floor have store room, library, 3 number of Science laboratory, math laboratory and 4 number of class rooms.

**2<sup>nd</sup> block:** It is two storied building having two staircase. In the ground floor there are PA system room, 4 number of class rooms, computer room, store room and 4 number of office rooms. Pa system room have two windows and two exits doors. Class rooms have two window in each room and two exits doors. The size of the window is 7x5 feet and 5x9 feet. 1<sup>st</sup> floor have Principal office and staff room.


**3<sup>rd</sup> block:** It is single storied building having five class rooms. There are one window in each class room and the size is 8x5 feet. Two side of the window have provision to open. There are 730 student and 52 staff.

#### The following Fire Safety equipment's which are installed in School Building:

01. 10 no's of fire extinguisher ABC Type 6 kg capacity is installed in the school building.
02. 03 number of submersible bore in the premises of the school building.
03. 50 thousand liters underground reserve water tank is installed in the school premises.
04. 08 number of sand bucket is installed in the school premises.

This office has no objection in issuance of **Fire NOC** in favour of the applicant.

**FIRE NOC is given in favour of Mahabodhi Residential School at Choglamsar, Leh** for period of One year from the issuance.

  
Director, F&ES, Ladakh  
PHQ, Agaling, Leh

#### **Copy to:**

01. Principal, Mahabodhi Residential School at Choglamsar, Leh for information and n/a.
02. Superintendent of Police, F&ES, Ladakh for information.
03. Office file.